

Energy performance certificate (EPC)

Unit 2
Cobbe Barns
Beddingham
Lewes
BN8 6JU

Energy rating

B

Valid until: **20 March 2032**

Certificate number: **2479-0061-0693-9226-1511**

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


295 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is B.



Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

22 | A

If typical of the existing stock

63 | C

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
-------------------	---------------------------

Building environment	Air Conditioning
----------------------	------------------

Assessment level	3
------------------	---

Building emission rate (kgCO ₂ /m ² per year)	55.01
---	-------

Primary energy use (kWh/m ² per year)	325
--	-----

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/8558-2214-1222-5415-1052\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Robert Beatty
Telephone	07768 053030
Email	bob.beatty@addam.co.uk

Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/013946
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

Assessment details

Employer	ADDAM Ltd T/A RBA Surveyors
Employer address	19 Benson Road, Henfield, West Sussex, BN5 9HY
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	22 February 2022
Date of certificate	21 March 2022
