

Energy performance certificate (EPC)

Unit 17-18
Basingstoke Business Centre
Winchester Road
BASINGSTOKE
RG22 4AU

Energy rating

C

Valid until: **24 August 2030**

Certificate number: **2167-3026-0807-0200-2625**

Property type

B8 Storage or Distribution

Total floor area


300 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is C.



Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

26 | B

If typical of the existing stock

76 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
-------------------	---------------------------

Building environment	Air Conditioning
----------------------	------------------

Assessment level	3
------------------	---

Building emission rate (kgCO ₂ /m ² per year)	81.47
---	-------

Primary energy use (kWh/m ² per year)	482
--	-----

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0210-0240-6872-7226-6006\)](/energy-certificate/0210-0240-6872-7226-6006).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Richard Siddall
Telephone	02476 233144
Email	richard.siddall@wensleylawz.com

Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/007509
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

Assessment details

Employer	Wensley And Lawz Ltd
Employer address	116 Walsgrave Road National Westminster Building Coventry CV2 4ED
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	22 June 2020
Date of certificate	25 August 2020
