
Energy performance certificate (EPC)				
	Energy rating	Valid until:	6 December 2029	
Regus Group Limited Compass House, Chivers Way Histon CAMBRIDGE CB24 9AD	C	Certificate number:	0670-0831-1329-7829- 1096	
Property type	E	31 Offices and Wo	orkshop businesses	
Total floor area	2	2,700 square met	res	

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

 33 B

 If typical of the existing stock

 95 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO2/m2 per year)	51.51
Primary energy use (kWh/m2 per year)	303

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/9290-7931-0421-1680-8070)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Andrew Ling	
Telephone	07767895320	
Email	andrewjling@hotmail.com	

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008701
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

ACI Reports Ltd
Suite A9, Allied Business Centre, Potter Place,
Skelmersdale, WN8 9PW
The assessor is not related to the owner of the
property.
26 November 2019
7 December 2019