

Property type	B1 Offices and Workshop businesses
Total floor area	5,846 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.

Under 0 A+

Net zero CO2

0-25 A

26-50 B

51-75 C

76-100 D

101-125 E 112 E

126-150 F

Over 150 G

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	29 B
If typical of the existing stock	85 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO2/m2 per year)	89.54
Primary energy use (kWh/m2 per year)	528

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation}}{\text{report (/energy-certificate/0210-7998-0448-9340-4094)}}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Michele Di Iasio
Telephone	02073971450
Email	michele@carbonprofile.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/020077
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment	
Employer	Carbon Profile Limited

Employer	Carbon Profile Limited
Employer address	Unit 2 Long Leys Farm Leys Road Oxford OX2 9QG
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	27 September 2018
Date of certificate	8 October 2018